



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190306006304-A1

Product

Button Switch

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGLA1-□□□□□;

Technical data

Ui:690V; Ith:10A; AC-15: Ue/Ie:AC400V/1.9A;
Ue/Ie:AC230V/3A; DC-13: Ue/Ie:DC230V/0.3A;
Ue/Ie:DC110V/0.6A;Uimp:4kV; Φ:22mm;IP40(key
button,tyep E);IP65(otherr button)

This is to certify that, on the basis of the tests undertaken as per Report No.
C-14201-DC195211, the submitted sample(s) of the above item complies with:

EN60947-5-1:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Dec.18,2019

Valid until: Jun.05,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>