

CERTIFICATE

of Conformity

Low Voltage Directive (EU) 2014/35

Registration No.: AN 50705990 0001
Report No.: CN25067K 001
Holder: Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China
Product: Auxiliary Contacts
(Auxiliary Contact)

Type designation listed on the next page

This certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical Report and documentation are at the License Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive (EU) 2014/35, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date: 2025-12-16

Certification Body

Yang Yongming

Yongming Yang



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.

CERTIFICATE

of Conformity

Low Voltage Directive (EU) 2014/35

Registration No.: AN 50705990 0001

Product: Auxiliary Contacts
(Auxiliary Contact)

Identification: Type Designation
F4-a b, F1-a b, F3-a b
a may be 0,1,2,3,4
b may be 0,1,2,3,4
"a" denotes the number of normally-open contacts
"b" denotes the number of normally-closed contacts

Trademark : (Tengen(Logo))
Serial number : Engineering samples

Ui : 690V
Uimp : 8kV
Ith : 10A
IP : 20

AC-15: Ue: AC380V Ie:0.95A
DC-13: Ue: DC220V Ie:0.15A
Conditional short-circuit current: 1kA

Issued in conjunction with TÜV Rheinland
license R 50705989 0001.



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.