

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50718181 0001

Berichtsnummer Report No.:

CN26I9XT 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

EN IEC 61095:2025

Geräteidentifikation
Product Identification
Produkt:

Magnetic Contactor

Product:

(Electromechanical Contactor for Household and Similar Purposes)

Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Technische Daten auf nächste(r) Seite(n) gelistet

Technical Data:

Technical Data is listed on the next page(s)

Gültig ab:

2026-03-13

Valid from:
Zertifizierungsstelle:

Certification body:

Ausstellungsdatum:

2026-03-13

Date of issue:

Ye Ding



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com
TÜVRheinland®
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50718181 0001

Berichtsnummer *Report No.:*

CN26I9XT 001

Produkt *Product:*

Magnetic Contactor
(Electromechanical Contactor for Household and Similar Purposes)

Modell *Type:*
Bezeichnung *Designation:*

Type Designation
TGCH1N-xy, TGCHK-xy
(x=32, 40, 63; y=10, 01, 20, 11, 02, 30, 40, 22, 31, 04)

Utilization Category	: AC-7a; AC-7b
Rated Operational Voltage	: AC250V(1P, 2P); AC400V(3P, 4P)
Rated Frequency	: 50/60Hz
Rated Insulation Voltage	: 500V
Rated Impulse Withstand Voltage	: 4kV
Rated Operational Currents	: When AC-7a, 32A(x=32), 40A(x=40), 63A(x=63); When AC-7b, 12A(x=32), 15A(x=40), 20A(x=63)
Conventional Free Air Thermal Current	: 63A
Rated Conditional Short-circuit Current	: 3kA

Anlage(Appendix) : 1

